



COMMUNITY RISK REDUCTION MANUAL
FIRE ALARM SYSTEMS
431.1 FIRE ALARM PLAN SYMBOLS
EFFECTIVE: APRIL 1, 2016
AUTHORIZED: *R. Pearce*

SCOPE

Fire alarm plan submittals.

PURPOSE

The purpose of this policy is to clarify the District's requirements related to fire alarm plan submittal and plan symbols.

BACKGROUND

The California Fire Code (CFC) specifies that fire alarm plans and shop drawings shall use the symbols found in National Fire Protection Association Standard 170, unless other symbols are approved by the enforcing agency.

Standard engineering guidelines and good business practice suggest that standardized plan symbols reduce confusion, speed plan review times, and increase efficiency. As such, all fire alarm plans and shop drawings submitted to the Tiburon Fire Protection District for review shall use the symbols found in National Fire Protection Association Standard 170. Failure to do so will result in rejection of plans.

REQUIREMENTS

All fire alarm plans and shop drawings submitted to the Tiburon Fire Protection District for review shall use the symbols found in National Fire Protection Association Standard 170.

These requirements apply to both required and voluntary systems.

CROSS REFERENCES

California Fire Code