

Fire Lane Requirements

410.1 PURPOSE AND SCOPE

Agency Content

This policy provides technical assistance to the minimum requirements found in Ordinance #129 and the 2019 California Fire Code, Chapter 5.

410.2 FIRE LANE SIGNAGE

Agency Content

Where required by the Fire Code official, a Fire Lane sign shall be manufactured to the following standard size, colors and language within the proper police jurisdiction's title and contact phone number within the District. Please see examples of Fire Lane Signage on the Prevention page of the Tiburon Fire District website.

410.3 PAINTED CURBS IN LIEU OF SIGNAGE

Agency Content

Curbs shall be painted in red with white lettering stating, "No Parking Fire Lane" when a sign is impractical or by approval by the Fire Code Official.